

**Government of Bihar**  
Public Health Division Muzaffarpur  
Water Quality Testing Report

Received Sample on date : 21.04.2023

District Muzaffarpur				Testing date - 21.04.2023												
SL. No.	Block	Location of Source	Type of Source	Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Kurhani	Trident Public School (Muzaffarpur)	Boring water	-	1	223	71.4	20	30	304	0.18	3.20	8	0.74	-	<1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-

Memo No. - 156 Muzaffarpur, Dated - 22/04/2023

Copy to Principal Trident Public School, H. Maniyari, (Muzaffarpur) to inform regarding reference to his letter No. - TFS/96-2023  
Dated :- 22.04.2023

*Aosh*  
Lab Assistant

*[Signature]*  
Chemist

*[Signature]*  
Assistant Engineer

P.H. Division, Muzaffarpur  
**ASSISTANT ENGINEER**  
PH DIVISION  
MUZAFFARPUR